

# CERTIFICATE FOR HYGIENIC INSPECTION

FOR THE PURPOSE OF TESTING AND OBSERVATION FOR THE PROOF  
OF THE CONTINUING CONFORMITY WITH THE VALID STANDARDS

for the company

**pfm medical CPP S.A.**  
**9, Allee du Quartz**  
**CH 2300 La Chaux-de-Fonds**

On April the 15<sup>th</sup>, 2010, the routine hygienic inspection of the air-conditioning-system and of the clean rooms at **pfm medical CPP S.A.** took place.

For the **clean room 1** (measuring points 1 to 14) the admissible particle concentrations of **ISO class 7** (corresponds to the withdrawn US Federal Standard 209 e, class 10,000) with 352,000 particles/m<sup>3</sup> for particles  $\geq 0.5 \mu\text{m}$ , 83,200 particles/m<sup>3</sup> for particles  $\geq 1 \mu\text{m}$  and 2,930 particles/m<sup>3</sup> for particles  $\geq 5 \mu\text{m}$  as well as

for the **NIVAROX room** (measuring points 15 to 20) the admissible particle concentrations of **ISO class 6** (corresponds to the withdrawn US Federal Standard 209 e, class 1,000) with 35,200 particles/m<sup>3</sup> for particles  $\geq 0.5 \mu\text{m}$ , 8,320 particles/m<sup>3</sup> for particles  $\geq 1 \mu\text{m}$  and 293 particles/m<sup>3</sup> for particles  $\geq 5 \mu\text{m}$

and for the **laminar flow cabinet** (measuring point 21) the admissible particle concentrations of **ISO class 5** (corresponds to the withdrawn US Federal Standard 209 e, class 100) with 3,520 particles/m<sup>3</sup> for particles  $\geq 0.5 \mu\text{m}$ , 832 particles/m<sup>3</sup> for particles  $\geq 1 \mu\text{m}$  and 29 particles/m<sup>3</sup> for particles  $\geq 5 \mu\text{m}$  were kept at all measuring points under operating conditions during the monitoring time and met the requirements of

**ISO 14644-1.**

The microbiological contamination of the room air in the clean room 1 and the NIVAROX room did not exceed 100 cfu (= colony forming units) per m<sup>3</sup> (with the exception of the measuring point 8/3 in the clean room and 20/1 in the NIVAROX room) and corresponded thereby to the request of

**EC GMP- guideline GRADE C.**


The clean rooms showed significant differential pressure towards uncontrolled area.

The microbiological investigations of the product-related surfaces documented a high level of the disinfection cleaning technology. The product-relevant values – with two exceptions - were under the limit value of 100 cfu per dm<sup>2</sup> (according to EC GMP-Guideline GRADE C).

The production conditions, documented by our measurements, showed that a contamination of the manufacturing goods by particles caused by the air conditioning system during the operation time was nearly not possible.

Aachen, April 30<sup>th</sup>, 2010



  
Dipl.-Biol. (corresponding to M.Sc.) Holger Stockem  
Technical Director